


Play Area Access Audit

Cornish Road Play Area



Chipping Norton PC

Mila Yearley



Play Area Access Audit

Site name: **Cornish Road Play Area**
Date of inspection: **04 December 2024**
Inspector: **Mila Yearley**

Site photograph and comments



Safety Audit Report

Play Area Access Audit

Score

90%

Accessible

Site name: **Cornish Road Play Area**
Date of inspection: **04 December 2024**
Inspector: **Mila Yearley**

Audit categories

Category	Comments	Score
Car Parking & Toilets	<i>No comment provided</i>	50%
Gates	No gates present.	100%
Access Route to the Play Area		100%
Access path surface		100%
Impact Attenuating Surfacing		100%
Seating and sight lines		100%
Vision-impaired aids		50%
Available activities		94%

Car Parking & Toilets

1 Is there parking available? **Yes**

Comments

On street

2 Is there designated parking available (at least 6% of total spaces)? **No**

Comments

This should be provided in accordance with BS 8300 -1:2018, 7.2.

3 Are the parking surfaces firm and level? **Yes**

4 Are toilets available with changing facilities? **No**

Comments

This should be provided in accordance with PD CEN/TR 16467:2018, clause 6.

Further guidance is available in BS 8300-2:2018. This assessment only notes the presence or absence of toilets and does not assess the suitability thereof.

Gates

5 Are entrances and gates at least 1000 mm wide? **Yes**

6 Can gates be opened from both sides with either hand? **None**

7 Can users on different sides see each other? **Yes**

8 Are the gates self-closing (ideally no quicker than 5 seconds)? **None**

Access Route to the Play Area

9 Is there a level access from the nearest public access path to and into the play area? **Yes**

10 Are obstacles easily detectable to visually impaired users (detectable with the sweep of a cane and with good visual contrast)? **Yes**

11 Are any upstands at least 150 mm high? **None**

12 Is there a continuous accessible route from the accessible entrance or car park? **Yes**

Comments

Dog grid and grass, both deemed accessible.

13 Are access routes free of steps, stairs, turnstiles or other features which constitute a barrier to access (unless an always accessible alternative is close by)? **Yes**

14 If the access route is long are there resting places not more than 50 metres apart? **Yes**

15 Are paths at least 1800 mm wide, and is that 1800 mm width clear up to a height of 2500 mm from the ground? **Yes**

16 Are there passing places at least 2000 mm long x 1800 mm wide? **Yes**

Access path surface

- 17** Is the surface suitable for year-round use? **Yes**



- 18** Do access paths extend to all accessible play equipment? **Yes**

Impact Attenuating Surfacing

- 19** Are there contained loose fill pits with raised edges? If so, are there ramped access points? **None**

- 20** Are other surface types suitable stable and level? **Yes**

Seating and sight lines

- 21** Are there open sight lines to allow carers to observe at a distance (to allow play without unnecessary control)? **Yes**

- 22** Is there accessible seating? **Yes**



- 23** Are there picnic tables or other such features which encourage the extension of time spent on site? **Yes**

Vision-impaired aids

- 24** Is tactile signage provided? **No**

- 25** Are there tactile surfaces and provision of contrasting colours? **Yes**

Available activities

- 26** Agility (e.g. traverse wall, nets, wobble boards) **Present and accessible**

- 27** Balancing (e.g. beam, poles, step logs) **Present and accessible**

- 28** Climbing (e.g. frame, wall, net, rope) **Present and accessible**

- 29** Crawling (e.g. tunnel, narrow bridge) **Present but not accessible**

30 Hanging
(e.g. overhead bars) **Present and accessible**

31 Jumping
(e.g. change in heights, gaps to jump over) **Present and accessible**

32 Meeting
(e.g. seats, boulders, logs) **Present and accessible**

33 Rocking
(e.g. seesaw, springer) **Present and accessible**

34 Rotating
(e.g. carousel, poles, discs) **Not present**

35 Sliding
(e.g. slides, poles, runways) **Present and accessible**

Comments

Slides accessible with help.

36 Speed
(e.g. swings, slides) **Present and accessible**

37 Swinging
(e.g. single user, multiple user) **Present and accessible**

38 Tactile
(e.g. water, sand, mud, grass, sound) **Not present**

39 Interesting landscape with a variety of accessible ground levels? **Present and accessible**

40 Quiet area **Present and accessible**

41 Ball Games **Present and accessible**



Playsafety Ltd
78 Shrivenham Hundred Business Park
Watchfield
SWINDON
SN6 8TY
+44 (0)1793 317470

Playsafety Ltd is licensed by RoSPA to trade as RoSPA Play Safety
© Playsafety Ltd